



DRINKING WATER ANALYSIS REPORT

Elemental Solutions, LLC

P.O. Box 59203, Schaumburg, IL 60173

www.elementalsolutionsllc.com

Prepared For:	Lincolnshire-Prairie View SD103
Report Attention To:	Scott Gaunky
Sample Collection Date:	5/10/2016

Analysis Parameter:	Lead by EPA 200.9 Rev. 2.2
Analysis Date:	5/12/2016

Sampling Location	Sample ID	Result ($\mu\text{g/L}$)	Comments
LPV SD#103/Daniel Wright/Outside Drinking Fountain	16E1009-01	<2.0	under the action limit
LPV SD#103/Daniel Wright/Kitchen	16E1009-02	<2.0	under the action limit
LPV SD#103/Half Day/HD Nurses Office Bathroom Sink	16E1010-01	<2.0	under the action limit
LPV SD#103/Half Day/HD Kitchen	16E1010-02	<2.0	under the action limit
LPV SD#103/Sprauge/LBS Kitchen	16E1011-01	<2.0	under the action limit