



DRINKING WATER ANALYSIS REPORT

Elemental Solutions, LLC
 P.O. Box 59203, Schaumburg, IL 60173
 www.elementalsolutionsllc.com

Prepared For:	Lincolnshire- Prairie View SD 103
Report Attention To:	Scott Gaunky
Sample Collection Date(s):	2/23/2017
Sample Collection Volume:	250mL

Analysis Parameter:	Lead by EPA 200.9 Rev. 2.2; MRL = 2ppb
Analysis Date(s):	2/28/2017, 3/2/2017

Sampling Location	Sample ID	Result (µg/L)	Comments
RM 120- Staff Lounge-Samp #1	17B2332-01	<2.00	under the action limit
RM 120- Staff Lounge-Samp #2	17B2332-02	<2.00	under the action limit
RM 122 -Samp #1	17B2332-03	18.26	above the action limit; re-sample
RM 122 -Samp #2	17B2332-04	<2.00	under the action limit
4th Gr. DF L Samp #1	17B2333-01	<2.00	under the action limit
4th Gr. DF L Samp #2	17B2333-02	<2.00	under the action limit
4th Gr. DF R Samp #1	17B2333-03	<2.00	under the action limit
4th Gr. DF R Samp #2	17B2333-04	<2.00	under the action limit
Gym DF Samp #1	17B2333-05	<2.00	under the action limit
Gym DF Samp #2	17B2333-06	<2.00	under the action limit
RM 1 Samp #1	17B2335-01	<2.00	under the action limit
RM 1 Samp #2	17B2335-02	<2.00	under the action limit
RM 2 Samp #1	17B2335-03	<2.00	under the action limit
RM 2 Samp #2	17B2335-04	<2.00	under the action limit
RM 3 Samp #1	17B2335-05	<2.00	under the action limit
RM 3 Samp #2	17B2335-06	<2.00	under the action limit
RM 4 Samp #1	17B2335-07	<2.00	under the action limit
RM 4 Samp #2	17B2335-08	<2.00	under the action limit
RM 5 Samp #1	17B2335-09	<2.00	under the action limit
RM 5 Samp #2	17B2335-10	<2.00	under the action limit
RM 6 Samp #1	17B2335-11	<2.00	under the action limit
RM 6 Samp #2	17B2335-12	<2.00	under the action limit
RM 8 Samp #1	17B2335-13	<2.00	under the action limit
RM 8 Samp #2	17B2335-14	<2.00	under the action limit
RM 10 Samp #1	17B2335-15	<2.00	under the action limit
RM 10 Samp #2	17B2335-16	<2.00	under the action limit
RM 11 Samp #1	17B2335-17	<2.00	under the action limit
RM 11 Samp #2	17B2335-18	<2.00	under the action limit
RM 13 Samp #1	17B2335-19	<2.00	under the action limit
RM 13 Samp #2	17B2335-20	<2.00	under the action limit
RM 14 Samp #1	17B2335-21	<2.00	under the action limit
RM 14 Samp #2	17B2335-22	<2.00	under the action limit
RM 15 Samp #1	17B2335-23	<2.00	under the action limit
RM 15 Samp #2	17B2335-24	<2.00	under the action limit
RM 16 Samp #1	17B2335-25	<2.00	under the action limit
RM 16 Samp #2	17B2335-26	<2.00	under the action limit



DRINKING WATER ANALYSIS REPORT

Elemental Solutions, LLC

P.O. Box 59203, Schaumburg, IL 60173

www.elementalsolutionsllc.com

Prepared For:	Lincolnshire- Prairie View SD 103
Report Attention To:	Scott Gaunky
Sample Collection Date(s):	2/23/2017
Sample Collection Volume:	250mL

Analysis Parameter:	Lead by EPA 200.9 Rev. 2.2; MRL = 2ppb
Analysis Date(s):	2/28/2017, 3/2/2017

Sampling Location	Sample ID	Result (µg/L)	Comments
RM 17 Samp #1	17B2335-27	<2.00	under the action limit
RM 17 Samp #2	17B2335-28	<2.00	under the action limit
RM 18 Samp #1	17B2335-29	<2.00	under the action limit
RM 18 Samp #2	17B2335-30	<2.00	under the action limit
RM 19 Samp #1	17B2335-31	<2.00	under the action limit
RM 19 Samp #2	17B2335-32	<2.00	under the action limit
RM 20 Samp #1	17B2335-33	<2.00	under the action limit
RM 20 Samp #2	17B2335-34	<2.00	under the action limit
RM 21 Samp #1	17B2335-35	<2.00	under the action limit
RM 21 Samp #2	17B2335-36	<2.00	under the action limit
RM 23 Samp #1	17B2335-37	33.83	above the action limit; re-sample
RM 23 Samp #2	17B2335-38	<2.00	under the action limit
RM 27 Samp #1	17B2335-39	<2.00	under the action limit
RM 27 Samp #2	17B2335-40	<2.00	under the action limit
RM 28 Samp #1	17B2335-41	<2.00	under the action limit
RM 28 Samp #2	17B2335-42	<2.00	under the action limit
RM 29 Samp #1	17B2335-43	<2.00	under the action limit
RM 29 Samp #2	17B2335-44	<2.00	under the action limit
RM 30 Samp #1	17B2335-45	<2.00	under the action limit
RM 30 Samp #2	17B2335-46	<2.00	under the action limit
RM 31 Samp #1	17B2335-47	<2.00	under the action limit
RM 31 Samp #2	17B2335-48	<2.00	under the action limit
RM 32 Samp #1	17B2335-49	<2.00	under the action limit
RM 32 Samp #2	17B2335-50	<2.00	under the action limit
RM 33 Samp #1	17B2335-51	<2.00	under the action limit
RM 33 Samp #2	17B2335-52	<2.00	under the action limit
RM 34 Samp #1	17B2335-53	<2.00	under the action limit
RM 34 Samp #2	17B2335-54	<2.00	under the action limit
Glass HW DF Samp #1	17B2335-55	<2.00	under the action limit
Glass HW DF Samp #2	17B2335-56	<2.00	under the action limit